


# RGS/MOS-cooling

## Results

February 03, 2003

L. Metcalfe



*XMM-Newton*

Science Operations & Data Systems Division  
Research & Scientific Support Department

Page 1

## **CONTENT :**

- \* immediate results of cooling**
- \* contamination**
- \* open points**

# RECOMMENDATIONS OF THE XMM NEWTON USERS GROUP re. COOLING

at UG Meeting of 16/17 September 2002

“The UG however encourages the Project to take all necessary steps to **make sure that the XMM data are of the best possible quality**, and at the same time strongly recommends that the Project take measures that **keep the impact on users** in terms of data delivery etc. **at a minimum.**”

“The Users Group feels that in order to make sure that the scientific capabilities of XMM-Newton can be maximally exploited **the MOS and RGS CCDs should be cooled** despite small remaining risks. Recommendations were formulated considering the expected scientific improvements as well as the delay in data delivery.”

Recommendation 2002-09-17/18: The Users Group appreciates the effort to maximise and to maintain the high performance of the instruments. Also, a steady data flow from XMM-Newton to the scientific community has now been achieved. **The impact of the cooling on the data delivery should thus be minimised.**

Action 2002-09-17/08: As far as data delivery is concerned, XMM-Newton SOC and XMM Newton SSC should evaluate the **possibility to deliver initially data with a preliminary calibration** and to reprocess such data after the cooled instruments are calibrated.

# THE PLAN



# COOLING

## MOS Instrument Settings

Focal plane temperature: -120 deg C

Voltages: unchanged

## RGS Instrument Settings

Focal plane temperature: -110 deg C

Voltages: some serial voltages adjusted

# BAD PIXELS

**MOS1 :**



**98  $\Rightarrow$  38**

**$\Rightarrow$  -61 %**

**MOS2 :**


**167  $\Rightarrow$  24**

**$\Rightarrow$  -86 %**




# ENERGY RESOLUTION-1

FWHM of the Mn K line (@5.9 keV)  
reduced from ~160eV to ~140eV.





# COOLING RGS


The RGS instruments' operational temperature was decreased in early November from -80°C to -110°C: Mkn421 was observed during the 9 hours necessary for decreasing the CCD temperature



RGS1




RGS2







RGS at its initial operating temperature of  $-80^{\circ}\text{C}$




RGS after cooling to  $-110^{\circ}\text{C}$



# PERIGEE T EXCURSIONS MOS1




# PERIGEE T EXCURSIONS MOS2




# MOS CTE degradation

high energy radiation degrades CTE continuously




# MOS CTI


parallel CTI reduced by factor 2 to 3 depending on CCD



# ENERGY RESOLUTION: MOS1




# ENERGY RESOLUTION: MOS2





# GAIN


**MOS1 energy scale monitoring with internal calibration source PAT1**



**RECONSTRUCTED LINE POSITION WITH SAS5.4\_REL**

# GAIN

MOS2 energy scale monitoring with internal calibration source PAT1



RECONSTRUCTED LINE POSITION WITH SAS5.4\_REL

# contamination monitoring



R  
G  
S


Nov	Dec	Jan	Feb	Mar	Apr	May	June	July	Aug
-----	-----	-----	-----	-----	-----	-----	------	------	-----



M  
O  
S




0091\_0095810301 & 0552\_0157161101  $\zeta$  Puppis stellar contamination monitor



# CCF Status


CCF	in work	DT	RN	CCR	RT	public	resp
EPN_CTI_0011	X	X	X	X	X	X	MK
EMOS_x_ADUCONV (12-18)	X	X	X	X	X	X	MK
EMOS_x_ADUCONV_0019	X	X	X	X	X	X	SS/MK
EMOS_x_CTI (7-15)	X	X	X	X	X	X	BA/MK
EMOS_x_BADPIX_0016	X	X	X	X	X	X	BA/MK
EMOS_x_HKPARMINT_0016	X	X	X	X	X	X	BA/MK
EMOS_x_QUANTUMEFF_0013	X	X	X	X	X	X	RS
EMOS_x_REDIST (13-19)	X	X	X	X	X	X	RS
EPN_QUANTUMEFF_0012	X	X	X	X	X	X	RS
related to cooling							

# Vela SNR pre and post-M1



**no evidence  
for a change  
in QE due to  
contamination  
going from  
Rev 533  
(pre-cooling)  
to Rev 534  
(post-cooling)**

# Vela SNR pre and post-M2




**no evidence  
for a change  
in QE due to  
contamination  
going from  
Rev 533  
(pre-cooling)  
to Rev 534  
(post-cooling)**

# RXj 0720.4-3125-M1

RXJ 0720 – M1


black – pre-cooling; red – post-cooling



drop in flux  
but spectral  
shape is the  
same




# RXj 0720.4-3125-M2



Entirely  
consistent


# N132D-M1



- redistribution problem?

- change between 474 and 535.

# N132D-M2



- redistribution problem?

- change between 474 and 535.

# OPEN POINTS (MOS)

## MOS:

- . Updates to CCD temperature calibration curves received from the Instrument team on 15/01/03 were implemented in Database Release 4.1 on 22/01/03.
- . Rxj0720.4-3125 MOS1/MOS2 post-cooling differences to be further investigated and understood with a view to giving an account of the effect to the User Community asap.
- . MOS QE increase on N132D below 0.5 keV, reaching 30% at 0.2 keV, to be further investigated and understood with a view to giving an account of the effect to the User Community asap.
- . check zeta pup observations

# OPEN POINTS (RGS)

## RGS:

- . Derive 2nd.-order refinements for the calibration of ODFs from the Cool-A to Cool-C 4 week period.
- . Confirm stability of wavelength calibration post-cooling.
- . Future NRCOs are needed for Zeta Puppis and Mkn421 when they become visible in 2003 April and May (Cool-D !?)
- . update the 1 X 1 Hot stuff:
  - run the Spectroscopy 1 X 1 Storage section/Spect 1 X 1
  - diagnostic 1 X 1 required

## **ACTIONS** (from cooling review)

**AI Wrap-1:** on the SOC (MK) to summarise current planning for CALCLOSED measurements with a view confirming PI agreement to the strategy at the EPIC/TTD/Calibration meeting.

**AI Wrap-2 :** on the SOC (MK) to specify any ongoing monitoring of CCD noise with a view to confirming a strategy with the PI at the upcoming EPIC TTD/Calibration Meeting.

**AI Wrap-3 :** on the SOC (MK) to specify current planning for bright-pixel monitoring with a view to confirming a strategy with the PI at the upcoming EPIC TTD/Calibration Meeting.

# CONCLUSIONS

- . Very strong improvements in instrument performances seen
- . Product distribution stopped December 03
- . Pipeline restarted with full re-calibration December 19
- . Product distribution resumed January 16, 4 working days beyond planned target
- . Some calibration features to be understood.